AG & GA SERIES
SPRINKLER GUARDS
Pendent & Upright



PRODUCT DESCRIPTION

Sprinkler Guards are designed to be assembled with sprinklers installed. They are made of thick steel welded and finished with a zinc coating. Other finishes are available.

The guards have the function of protecting the sprinklers in places where they may be exposed to physical damage.

INSTALLATION

With the two-pin unhooked, slightly open the guard. Insert the guard into the installed sprinkler between the thread and the wrench frame part of the sprinkler. The guard should have 4 points of contact with the frame.


Fit the two-pins in place. The guard is now installed securely. If the pins require so much force to open or close, slightly flex the wires on both sides of the clip, and then open and close the pins.


FINISH[1]

Guard	**Standar:**	Zinc Plated

1. Other Finishes available under request.

DIMENSIONS





C/Alfoz de Bricia nº4 | P.I. Villalonquéjar | 09001 Burgos (Spain) | Tlfno: +34 947 28 11 08

AG FIRE SPRINKLER

AG Fire Sprinkler offers a wide selection of components. Then a list of products is presented by AG Fire Sprinkler, we can offer all these components, made with precision to protect people, anywhere, anytime.

- Sprinklers
  - Basic
  - Extended Coverage
  - Storage
  - Dry
  - Accessories
- System valves
  - Wet
  - Dry
  - Preaction Equipment
  - Accessories
- Spray System Open Nozzles
  - High Velocity Nozzles
  - Medium Velocity Nozzles
  - Window Nozzles
  - Hydroshield Nozzles
  - Mushroom Type Nozzles
- Foam equipment
  - Bladder Tanks
  - Proportioners for Bladder Tanks
  - Foam Discharge Equipment
  - Foam Concentrates
- Deluge equipment for Water Spray and Foam
  - Clapper Deluge Valves
  - Diaphragm Deluge Valves
- Monitors
  - Manual Monitors
  - Remote Monitors
  - Monitor Towers
  - Monitors Trolleys
- Valves
  - Butterfly Valves
  - Gate Valves
  - Check Valves
  - Pressure Control Valves
  - Test and Drain
  - Hose, Hydrant and Fire Connection Valves
  - Fire Department Connections

The equipment presented in this bulletin is to be installed in accordance with the latest published Standard of the National Fire Protection Association, Factory Mutual Research Corporation, or other similar organizations and also with the provisions of governmental codes or ordinances whenever applicable.
This documentation is not contractual. AG Fire Sprinkler reserves the right to any kind of change without notice.

C/Alfoz de Bricia nº4 | P.I. Villalonquéjar | 09001 Burgos (Spain) | Tlfno: +34 947 28 11 08