CALLISONRTKL WSP JLL HSBC AWSHMD SHAKER SURFACE PROP NeXTeP CONSTRUCTION

Project Name:	HSBC Project Nile FOP	Project Number:	100468

Material Approval Request
MAR

Contractor:	Nextep	Date:	29-Jul-21
Transmittal No:	MAR-002	Action Code Key:	
Rev:	00	A	Approved
Submittal Type:	Material	B	Approved with comments
Discipline:	Mechanical	C	Rejected
Transmitted for:	Approval	D	for Information

By Contractor:

Subject:	GROOVED FITTINGS

SL	DESCRIPTION	MANUFACTURE / SUPPLIER:	SPECS REF.	DATA SHEET	SAMPLE	MEASUREMENTS
1	GROOVED FITTINGS	FIRE KING VIKING	SECTION 210500 COMMON WORKS FOR FIRE SUPPRESSION	☑	☐	NO.
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	

For Contractor:

Name: **Title:** **Signature:** **Date:**

By Consultant:

Comments:

Code (B)

Approved	Approved with Comments	Rejected	For Info
☐	☑	☐	☐

Copies to:					
	Client ☐		Arch Consultant ☐		Others: ☐
	Project Manager ☐		MEP Consultant ☐		

For Consultant: SLG: Refer to our Comments on attached (A4) sheet.

Name: Mohamed Sales **Title:** **Signature:** **Date:** 29/7

By PM:

For PM:

Comments:

Name: **Title:** **Signature:** **Date:**

- Approval and / or correction of comments shall not relieve the contractor of his liabilities under the contract.
- Approval and / or comments on the submittal shall not constitute authorization of any variation to the contract documents.

محمد/ هشام صدار
مساعد المدير للمشروعات العامة
٢٣/١/٢٠٢٢

الهيئة الهندسية للقوات المسلحة
إدارة المشرعـــات الكـــبرى
فـــرع الـميكانيكا والكـــهربـاء
القيد: م.ك /مشروعات/٢٠٢٢/٩٣١
التاريخ: ٢٣ / ١ / ٢٠٢٢م.

إلى مكتب/ السيد مساعد المدير للإنتاج و التنفيذ

(قطاع تنفيذ رقم ١٤)

إيماءً إلى خطابكم رقم (٩٤) بتاريخ ٢٠٢٢/١/٢٠ بشأن مشروع إنشاء مبانى خدمات الحى الحكومى بالمحور الرئيسى بالعاصمة الإدارية الجديدة

يرجى التكرم بالاحاطة بالآتي:

لا مانع من اعتماد العرض الفنى لكلاً من :

١- (GROOVED FITTING) ماركة (VIKING).

٢- (HANGER SUPPORT) ماركة (DIAMOND).

الخاصة بمشروع مركز مطاعم و كافيهات و ماركت (B05).

مع الإلتزام بتنفيذ مواصفات الكود المصرى والكود الامريكى (NFPA) ومقايسة الاعمال.

مع وافر التحية ،،،

التوقيع ( )
عميد/ محمد جمـــال سلطان
رئيس فرع الميكانيكا والكهرباء

التوقيع ( )
عميد/ اسامة محـــمد الجنزورى
مساعد المدير للمشروعـــات

مساعد المدير للإنتاج والتنفيذ
القيد: ٥١
التاريخ: ٢٤/ ١/ ٢٠٢٢

مساعد المدير للمشروعات
القيد: م٣/ ١٤٢
التاريخ: ٢٤/ ١/ ٢٠٢٢

Scanned with CamScanner

M dern Management Technology

طلب اعتماد مواد

مراجعة	رقم التقديم
0	MS-01
التاريخ	14-11

	الاعتماد
A	معتمد
B	معتمد بملحوظات
C	يعاد تقديمه
D	مرفوض

المالك: مدرسة نور العلم بالسادات

استشاري المالك: EEPM

الجهة المنفذة: شركة تكنولوجيا الادارة المتطورة (MMT)

مسلسل	رقم البند في المقايسة	اسم المورد	بلد المنشأ	الوصف	الاعتماد
1	F-0-A-1-G	VIKING	اتحاد اوربي	GROVED FITTING	
2					
3					
4					

المرفقات

الكتالوج و المواصفات الفنية وشهادات الاختبار وشهادات المنشاء

المقاول: شركة تكنولوجيا الإدارة المتطورة MMT التاريخ: 14-11

المستلم: مكتب EEPM التاريخ: 2021.11.14

الملاحظات وكود الاعتماد

ملاحظات الاستشاري

* تعتمد جميع منتجات Grooved Fittings & Grooved Coupling ماركة Viking ذات ضغط التشغيل الذي لا يقل عن 300psi.
* على المقاول تقديم شهادة بلد المنشأ للمورد المشروف.
* على المقاول مراعاة تعليمات الشركة الصانعة عند التركيب.
* على المقاول تقديم شهادة ضمان لا تقل عن 10 سنوات ضد العيوب الصناعية.
* على المقاول تقديم عدد 2 نسخة إضافية حيث لم يقدم سوى نسخة واحدة فقط.

ومرفق اعتماد لوحة العينات.

التاريخ: 2021

eepm

م. محمد

MATERIAL SUBMITTAL FORM – (MAR)

Contract No.: PEG 1152	Package No.: CP01

TO: Eng. Mohamed Elsouly - Hill International	**SUBMITTAL NO.:** PEG-1152-CP01-CN-HA-MAR-0138
FROM: HA-JV	**DATE:** 4 - Jan. 22
TITLE: Grooved Fitting for UL / FM For Fire Fighting	**REVISION NO:** Rev. 00
	C/REF.:

MATERIAL SUBMISSION DESCRIPTION

Discipline: Mechanical

Description of Material: Grooved Fitting for UL / FM For Fire Fighting.

Manufacturer: Viking	**Supplier / capital Guard**
Specification: 15310	**BOQ Ref: 15310**
Description of Attachments: 204 A4 papers	**Description of Samples:** N/A
Specification Comparison Sheet	
Comparison in case of Alternative Submittal	
CONTRACTOR SIGNATURE:	**Date:**
LEED SIGNATURE:	**Date:** ☐ A ☑ N/A

HASSAN ALLAM CONTROL COPY HA-JV AAIB ONE NINETY PROJECT DATE: / /20

Hill Receive:	Consultant Receive:	Returned From Consultant:	Contractor Receive:
Hill International 4 JAN 2022 AAIB Project Received	Received 1233 - Arab African International Bank - New Cairo 04 JAN 2022	Hill International 13 JAN 2022 AAIB Project Received	Received 13 JAN 2022 HA-JV AAIB ONE NINETY PROJECT

EMPLOYER'S COMMENTS – (Optional)

Name: **Signature:** **Date:**

PROJECT MANAGEMENT CONSULTANT'S REVIEW - (Hill International)

Name: MEP manager Hossam ELganzoury **Signature:** **Date:** 13. 1. 2. 22

SUPERVISION CONSULTANT'S COMMENTS

Rdv to attached Cover Corr reply

☐ A-APPROVED ☑ B –APPROVED AS NOTED, WORK MAY PROCEED – INCORPORATE COMMENTS ☐ C- REVISE / RESUBMIT ☐ D- REJECTED

For & On behalf of *(Specify)*

Reviewer	DATE	PROJECT MANAGER	DATE
For E. Hany			

البنك العربي الافريقي الدولي arab african international bank	AAIB 1-Ninety Head Quarter	HASSAN ALLAM CONSTRUCTION | HASSAN ALLAM TECHNOLOGIES	EHAF CONSULTING ENGINEERS / SHAKER CONSULTANCY GROUP	HILL International

MATERIAL SUBMITTAL FORM – (MAR)

Contract No.: PEG 1152 | **Package No.: CP01**

TO: Eng. Mohamed Elsouly - Hill International	**SUBMITTAL NO.:** PEG-1152-CP01-CN-HA-MAR-0138
FROM: HA-JV	**DATE:** 4 - Jan. 22
TITLE: Grooved Fitting for UL / FM For Fire Fighting	**REVISION NO:** Rev. 00
	C/REF.:

HASSAN ALLAM CONTROL COPY AAIB ONE NINETY PROJECT HA-JV DATE: / /20

MATERIAL SUBMISSION DESCRIPTION

Discipline: Mechanical

Description of Material: Grooved Fitting for UL / FM For Fire Fighting.

Manufacturer: Viking	**Supplier / capital Guard**
Specification: 15310	**BOQ Ref: 15310**
Description of Attachments: 204 A4 papers	**Description of Samples:** N/A

Specification Comparison Sheet

Comparison in case of Alternative Submittal

CONTRACTOR SIGNATURE: Date:

LEED SIGNATURE: Date: ☐ A ☑ N/A

Hill Receive:	Consultant Receive:	Returned From Consultant:	Contractor Receive:
International 4 JAN 2022 AAIB Project Received	Received 1233 - Arab African International Bank - New Cairo 04 JAN 2022		

EMPLOYER'S COMMENTS – (Optional)

Name: **Signature:** **Date:**

PROJECT MANAGEMENT CONSULTANT'S REVIEW - (Hill International)

Name: **Signature:** **Date:**

SUPERVISION CONSULTANT'S COMMENTS

Rdv to attached Comm Copy reply

☐ **A-APPROVED** ☑ **B –APPROVED AS NOTED, WORK MAY PROCEED – INCORPORATE COMMENTS** ☐ **C- REVISE / RESUBMIT** ☐ **D- REJECTED**

For & On behalf of *(Specify)*

Reviewer	DATE	PROJECT MANAGER	DATE

البنك العربي الافريقي الدولي arab african international bank	AAIB 1-Ninety Head Quarter	HASSAN ALLAM CONSTRUCTION | HASSAN ALLAM TECHNOLOGIES	EHAF CONSULTING ENGINEERS / SHAKER	Hill International

MATERIAL SUBMITTAL FORM – (MAR)

Contract No.: PEG 1152	Package No.: CP01

TO: Eng. Mohamed Elsouly - Hill International	SUBMITTAL NO.: PEG-1152-CP01-CN-HA-MAR-0138
FROM: HA-JV	DATE: 4 - Jan. 22
TITLE: Grooved Fitting for UL / FM For Fire Fighting	REVISION NO: Rev. 00
	C/REF.:

MATERIAL SUBMISSION DESCRIPTION

Discipline: Mechanical	
Description of Material: Grooved Fitting for UL / FM For Fire Fighting.	
Manufacturer: Viking	Supplier / capital Guard
Specification: 15310	BOQ Ref: 15310
Description of Attachments: 204 A4 papers	Description of Samples: N/A
Specification Comparison Sheet	
Comparison in case of Alternative Submittal	
CONTRACTOR SIGNATURE:	Date:
LEED SIGNATURE: for m. Yusef	Date: ☐ A ☑ N/A

HASSAN ALLAM CONTROLLED COPY FOR PURCHASE ONLY PROJECT DATE: 7/1/22

Hill Receive:	Consultant Receive:	Returned From Consultant:	Contractor Receive:

EMPLOYER'S COMMENTS – (Optional)

Name: Signature: Date:

PROJECT MANAGEMENT CONSULTANT'S REVIEW - (Hill International)

Name: Signature: Date:

SUPERVISION CONSULTANT'S COMMENTS

- Country of origin shall be provided
- Method statement shall be provided
- Sample of product shall be provided for approval
- updated for FM&UL Certification
- selection of Item will be used on the project

☐ A-APPROVED ☑ B –APPROVED AS NOTED, WORK MAY PROCEED – INCORPORATE COMMENTS ☐ C- REVISE / RESUBMIT ☐ D- REJECTED

For & On behalf of *Specify)*

....

Reviewer DATE PROJECT MANAGER DATE

- Gasket certification should be provided.

(مشروع الحي اللاتيني) المنطقة الأولى - مدينة العلمين الجديدة

SAMCRETE

ECG المجموعة المصرية للاستشاريين
ENGINEERING CONSULTANTS GROUP, S.A.



المالك: جهاز مدينة العلمين الجديدة

الإستشاري: جماعة المهندسين الإستشاريين

المقاول: سامكريت-مهندسون ومقاولون

ECG ENGINEERING CONSULTANTS GROUP S.A.
مشروع الحي اللاتيني - مدينة العلمين الجديدة
(2504)
RECEIVED
Date 9-6-21 Time

(Submittal - MAT)

طلب اعتماد مـــــواد

إلى الإستشارى :-	جماعة المهندسين الإستشاريين ECG	مـن المقاول العام :	سامكريت-مهندسون ومقاولون

رقم الطلب	SAM-ECG-MAT-MECH-027	الإصدار	0	التاريخ	29-May-21
الموضوع	Grooved		المرفقات		A4 + CD

نوع الاعمال		إنشـــائى		معمارى		كهرباء		ميكانيكا	■	مساحة		اخرى	

م	البيـــان / الوصف	عدد النسخ	المصنع / بلد الصنع	رمز المواصفات	رمز المقايسة
1	Grooved	3	Capital Guard		

تعهد المقاول: المستندات المرفقة تنسيقها ومراجعتها من حيث تطابقها مع العقد وتعتبر مقبولة للاستخدام فى المشروع من قبل المقاول

المقاول

مدير قسم الاليكتروميكانيكال: نصر احمد عبد الغفار

مدير المكتـــب الفنـــى: نصر احمد عبد الغفار

استلام الإستشارى | بواسطة: | التوقيع: | بتاريخ: 5/6/21

ملاحظات الإستشارى

* Refer to comments at attached A4.

الإستشارى المختص | الإعتماد بواسطة: م/ محمد | التوقيع: | بتاريخ: 3/6/21

أ | معتـــمد

ب | ✓ | معتمد مع ملاحظات - يمكن للمقاول ان يستمر بناءا على الملاحظات

ج | يعاد التقديم مرة اخرى بعد اتمام الملاحظات

د | الطلب مرفوض

اعتماد الإستشارى	م/.....	بتاريخ 1../6../2021
استلام المقاول	الإستلام بواسطة :	بتاريخ ...../...../.....

HEAD OFFICE ENGINEERING CONSULTANTS GROUP
APPROVED AS NOTED
INCORPORATION
BY
Permission to proceed does not relieve the contractor from his contractual obligations

التوزيع قبل الاعتماد :

المـــالك :	الإستشـارى :

التوزيع بعد الاعتماد :

المـــالك	المقـــاول	الإستشـــارى					
		مدنى	معمارى	كهرباء	تكييف	ميكانيكا	تخطيط	Q.S

ALAMEIN LATIN PROJECT
Received
Time 12:0
1 6 21
Engineers & Contractors

Submittal for approval of materials

Date: 28/10/2021

Request no: ALDahab-Mat-MFF-004-00

Project no. & title: PE20851C (the presidential Park)

Employer:	Engineer:	Contractor:
ACUD ADMINISTRATIVE CAPITAL	dar	الدهب للمقاولات والأعمال الهندسية

1. Material description (one item only on this form) :

Subject ERW Steel Pipes fittings , Drein Valve , Fire Extinuisher , Pressere Gauge , Sprinklers , temper Switch and Cabinet

Area of application : all project (with DATA SHEET ~~No~~ Sample)

الدهب للمقاولات والأعمال الهندسية

Drawing ref. : B.O.Q. ref. no.:

Specification Ref. : Standards: UL & FM

Attach all relevant technical literature marked to identify relevant description, current Test Certificates, samples as appropriate.

2. Manufacturer / supplier

Company Name : Siam , Giacomini , Bavaria , AGF , Rapidrop , Potter and Bavaria

Address :

Local agent : EGY Gulf for Engineering and industries

dar Dar Al-Handasah

20 OCT 2021

RECEIVED

3. Delivery :

Country of origin : Saudi Arabia

Availability ○ Locally Manufactured ◉ Overseas

Delivery : Ex-works/ total duration [ ]

Estimated time of arrival on site [ ]

Program : Date material required on site [ ]

Latest date for order [ ]

We certify that the above submitted items have been reviewed in detail and are correct and in strict conformity with the contract drawings and specifications except as otherwise stated; also that the material sources indicated above have been reviewed in detail and that they will supply the submitted items in conformity with the above and deliver same timely.

Submitted by : Signature:

4. Engineer's Representative comments:

Threaded fittings : SIAM upto 65 mm

Grooved Fittings : viking from 65 mm

Signature: Date:

- ☐ Approved
- ☐ Approved as noted
- ☐ Revise and resubmit
- ☐ Rejected
- ☐ Sample required
- ☐ Tests required
- ☐ Additional information required
- ☐ Manufacturer's guarantee required

Approval shall not relieve Contractor of his liabilities under the Contract or constitute authorization of any change to Contract Documents.

dar